

Customer Connection Requirements

Fleming County Water Association
2772 Morehead Road,
PO BOX 327
Flemingsburg, KY 41041
606-845-3981
kcornette@richm.twcbc.com

1. Fleming County Water Provides a Connection of a $\frac{3}{4}$ " Male Pipe Thread on the Copper Setter inside the Meter Well. The Customer needs a $\frac{3}{4}$ Female Pipe Thread to whatever Piping the customer is using. The Customer responsibility of maintenance starts with fitting that attaches to the $\frac{3}{4}$ " Male Pipe Thread on the setter and the customer supplied water line.
2. The applicant/customer must furnish and lay the necessary pipe to make the connection from the point of service to the point of usage and be financially responsible for all costs associated with the installation and maintenance of his/her service line plumbing, including a pressure regulator, a shut-off valve and one-way check valve, installed on his/her property beginning at the outlet side of the water meter. The service line must be kept in good repair and in accordance with utility and Public Service Commission rules and regulations.
3. All service lines on the customer's side of the meter must consist of copper or PVC pipe with a rating of no less than 200 psi, and should not be less than $\frac{3}{4}$ " inches.
4. Absolutely no galvanized pipe or fittings can be used in the installation.
5. The water line must be buried in a ditch that is at a minimum of 30 inches in depth.
6. The water line must be a minimum of 200 psi line.
7. Two shut-off valves must be installed on the customer side. The customer is not to rely on the meter shut off valve.
8. The customer is required to have their own pressure regulator, A one-way check valve and shut off valve.
9. The water line may be visually inspected by the utility.